



Center for  
Testing and  
European  
Certification

**CENTER FOR TESTING AND EUROPEAN CERTIFICATION  
NOTIFIED BODY NB 1871**


**23, Sv.Patriarh Evtimii Blvd., Stara Zagora 6000, Bulgaria  
tel. +359 42 620 368, fax +359 42 602 377, e-mail: ctec@ctec-sz.com**

**ЛАБОРАТОРИЯ ЗА ИЗПИТВАНЕ НА СТРОИТЕЛНИ ПРОДУКТИ**

гр.Стара Загора, ул.“Индустириална“ № 2

ИА БСА е страна по многостранно споразумение ЕА МЛА

Сертификат за акредитация, рег. No 252 ЛИ /17.06.2022г., валиден до 17.06.2026г,  
издаден от ИА БСА, съгласно изискванията на стандарт БДС EN ISO/IEC 17025:2018



Page 1 of 2

**REPORT**

**FROM TESTING**

**№ 1 16 0895 / 11.07.2024**

- 1. Product of testing:** Waterproofing products
- 2. Information provided by the applicant about the product:** Polymer modified bituminous thick coatings for waterproofing BEO ISOL UNIVERSAL. Manufacturer: BEO SAMPLER DOO, Jurija Gagarina 231/329, Belgrade, Serbia
- 3. Applicant of the testing:** BEO SAMPLER DOO, Jurija Gagarina 231/329, Belgrade, Serbia.
- 4. Application for the testing:** № 3-0484 / 29.05.2024, without report from sampling from CPTL
- 5. Location of performance of the testing:** Construction Product Testing Laboratory (CPTL)
- 6. Test methods:**  
БДС EN 15280:2011 Polymer modified bituminous thick coatings for waterproofing - Determination of watertightness
- 7. Date of delivery of the sample for testing to the laboratory:** 29.05.2024
- 8. Description of the received sample:** 7 kg
- 9. Date/s/ of performance of the testing:** 04.07.2024 ÷ 10.07.2024

Head of laboratory: .....

(eng. H. Angelova)



**10. Results from testing:**

№	Name of testing/ characteristic	Unit of measure	Test method	Diary sample №	Test results (uncertainty)	Environmental conditions
1	2	3	4	5	6	7
1.	Water impermeability – visible crossing the water at 0.0075 N/mm <sup>2</sup> pressure for 24h	yes / no	БДС EN 15820:2011	0695-0	yes, passed	t°= (25 ± 0.2)°C RH= (53 ± 1.5)%

**11. Additions to, deviations, or exclusions from the test methods: No**

**12. Additional information required by the test method: No**

Note I: The test results apply to the tested samples only.

Note II: The report from testing shall not be reproduced except in full, without approval of the laboratory.

Note III: The laboratory is not responsible for the information presented by the applicant in p. 2, for the influence of this information on the validity of the results, as well as for the taking of samples when they are provided by the applicant.

„В случай на недоразумение е валидна версията на български език / In case of misunderstanding, the Bulgarian version is valid“

Tested by: .....  
( I. Ivanov )

Head of laboratory: .....  
( eng. H. Angelova )



END